



Columbia Adair Utilities District Water Quality Report for year 2014

KY0010702

Water - Essential for Life

Meetings: Columbia Adair Utilities Office

Meeting Dates and Time: Second Thursday each month 6:00 PM

Manager: **Lennon Stone**

Phone: **270-384-2181**

CCR Contact: **Lennon Stone**

Phone: **270-384-2181**

This report is designed to inform the public about the quality of water and services provided on a daily basis. Our commitment is to provide our customers with a safe, clean, and reliable supply of drinking water. We want to assure that we will continue to monitor, improve, and protect the water system and deliver a high quality product. Water is the most indispensable product in every home and we ask everyone to be conservative and help us in our efforts to protect the water source and the water system.

In 2014 Columbia Adair Utilities District(A=table page) purchased water from four different sources. Columbia Adair Water Commission(B=table page), pumps its water from Green River. City of Russell Springs(C=table page), which purchases its water from the regional water plant in Jamestown KY; City of Jamestown(D=table page), which pumps its raw water from Lake Cumberland; Campbellsville Municipal Water & Sewer(E=table page), which pumps its water from two sources, the City Lake and Green River Reservoir. All of our producers are treating moderate rated surface waters which would have a low contamination susceptibility. All of our suppliers meet or exceed EPA standards in water treatment technologies and practices. The complete source water assessment for all of our suppliers can be obtained at the Lake Cumberland Area Development District office located in Russell Springs, KY. Telephone number 270-866-4200.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects may be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and may pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include: Microbial contaminants, such as viruses and bacteria, (sewage plants, septic systems, livestock operations, or wildlife). Inorganic contaminants, such as salts and metals, (naturally occurring or from stormwater runoff, wastewater discharges, oil and gas production, mining, or farming). Pesticides and herbicides, (stormwater runoff, agriculture or residential uses). Organic chemical contaminants, including synthetic and volatile organic chemicals, (by-products of industrial processes and petroleum production, or from gas stations, stormwater runoff, or septic systems). Radioactive contaminants, (naturally occurring or from oil and gas production or mining activities).

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water to provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Some or all of these definitions may be found in this report:

Information About Lead:

Maximum Contaminant Level (MCL) - the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - the level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Below Detection Levels (BDL) - laboratory analysis indicates that the contaminant is not present.

Not Applicable (N/A) - does not apply.

Parts per million (ppm) - or milligrams per liter, (mg/L). One part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) - or micrograms per liter, (µg/L). One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Parts per trillion (ppt) - one part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.

Parts per quadrillion (ppq) - one part per quadrillion corresponds to one minute in 2,000,000,000 years or one penny in \$10,000,000,000,000.

Picocuries per liter (pCi/L) - a measure of the radioactivity in water.

Millirems per year (mrem/yr) - measure of radiation absorbed by the body.

Million Fibers per Liter (MFL) - a measure of the presence of asbestos fibers that are longer than 10 micrometers.

Nephelometric Turbidity Unit (NTU) - a measure of the clarity of water. Turbidity has no health effects. However, turbidity can provide a medium for microbial growth. Turbidity is monitored because it is a good indicator of the effectiveness of the filtration system.

Variances & Exemptions (V&E) - State or EPA permission not to meet an MCL or a treatment technique under certain conditions.

Action Level (AL) - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system shall follow.

Treatment Technique (TT) - a required process intended to reduce the level of a contaminant in drinking water.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Your local public water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Spanish (Español) Este informe contiene información muy importante sobre la calidad de su agua beber. Tradúzcalo o hable con alguien que lo entienda bien.

The data presented in this report are from the most recent testing done in accordance with administrative regulations in 401 KAR Chapter 8. As authorized and approved by EPA, the State has reduced monitoring requirements for certain contaminants to less often than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data in this table, though representative, may be more than one year old. Unless otherwise noted, the report level is the highest level detected.

A=Columbia Adair Utilities District KY 0010702

B=Columbia Adair Water Commission KY0011016

C=City of Russell Springs KY1040377

D=City of Jamestown KY1040210

E=Campbellsville Water & Sewer KY1090060

	Allowable Levels	Source	Highest Single Measurement	Lowest Monthly %	Violation	Likely Source of Turbidity
Turbidity (NTU) TT	No more than 1 NTU*	B=	0.09	100	No	Soil runoff
* Representative samples of filtered water	Less than 0.3 NTU in 95% monthly samples	C=	0.03	100	No	
		D=	0.03	100	No	
		E=	0.3	100	No	

Regulated Contaminant Test Results

Contaminant [code] (units)	MCL	MCLG	Source	Report Level	Range of Detection	Date of Sample	Violation	Likely Source of Contamination
-------------------------------	-----	------	--------	--------------	--------------------	----------------	-----------	--------------------------------

Microbiological Contaminants

Total Coliform Bacteria # or % positive samples	1	0	A=	1	N/A	June/Oct	No	Naturally present in the environment
			D=	1	N/A	Mar		

Radioactive Contaminants

Alpha emitters [4000] (pCi/L)	15	0	C=	0.62	N/A	Apr-13	No	Erosion of natural deposits
			E=	0.40	0.2 to 0.7	May-09		
Combined radium (pCi/L)	5	0	C=	0.82	N/A	Apr-13	No	Erosion of natural deposits
			E=	0.10	0 to 0.2	Nov-09		
Uranium (µg/L)	30	0	C=	0.012	N/A	Apr-13	No	Erosion of natural deposits
			E=	0.63	0.1 to 0.9	Feb-09		

Inorganic Contaminants

Barium [1010] (ppm)	2	2	B=	0.01	0.01 to 0.01	Mar-14	No	Drilling wastes; metal refineries; erosion of natural deposits
			C=	0.022	0.022 to 0.022	Feb-14	No	
			D=	0.022	0.022 to 0.022	Feb-14	No	
			E=	0.010	0.01 to 0.01	Feb-14	No	
Copper [1022] (ppm) sites exceeding action level 1	AL = 1.3	1.3	A=	0 (90 th percentile)	0 to 1.5	Jun-14	No	Corrosion of household plumbing systems
Fluoride [1025] (ppm)	4	4	B=	0.94	0.70 to 1.13	Jun-14	No	Water additive which promotes strong teeth
			C=	1.1	1.1 to 1.1	Feb-14	No	
			E=	0.92	0.65 to 1.16	Jun-14	No	
Lead [1030] (ppb) sites exceeding action level 1	AL = 15	0	A=	11 (90 th percentile)	0 to 21	Jun-14	No	Corrosion of household plumbing systems
Nitrate [1040] (ppm)	10	10	B=	0.95	0.95 to 0.95	Mar-14	No	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
			C=	0.58	N/A	Feb-2014	No	
			D=	0.58	0.58 to 0.58	Jan-2014	No	
			E=	0.610	0.61 to 0.61	May-14	No	

Synthetic Organic Contaminants including Pesticides and Herbicides

Atrazine [2050] (ppb)	3	3	B=	0.25	N/A	N/A	No	Runoff from herbicide used on row crops
			E=	0.10	BDL to 0.25	Aug-14	No	

Disinfectants/Disinfection Byproducts and Precursors

Total Organic Carbon (ppm) (report level=lowest avg. range of monthly ratios)	TT*	N/A	B=	1.24	0.97 to 1.53	N/A	No	Naturally present in environment.
			C=	1.1	0.76 to 1.56	Monthly	No	
			D=	1.10	1.00 to 1.56	N/A	No	
			E=	1.26	1.00 to 1.90	N/A	No	

*Monthly ratio is the % TOC removal achieved to the % TOC removal required. Annual average of the monthly ratios must be 1.00 or greater for compliance.

Chlorine (ppm)	MRDL = 4	MRDLG = 4	A= (highest average)	1.42	0.52 to 2.23	N/A	No	Water additive used to control microbes.
HAA (ppb) (all sites) [Haloacetic acids]	60	N/A	B= C= D= E= (system average)	24 36 45 39	24 to 24 6 to 58 2 to 79 12 to 44 (range of system sites)	N/A N/A N/A N/A	No No No No	Byproduct of drinking water disinfection
HAA (ppb) [Haloacetic acids] (Individual Sites)	60	N/A	A= (locational average)	48	12 to 82 (range of individual sites)	N/A	No	Byproduct of drinking water disinfection
THM (ppb) (all sites) [total trihalomethanes]	80	N/A	B= C= D= E= (system average)	34 44 56 48	34 to 34 27 to 57 11 to 110 11 to 66 (range of system sites)	N/A N/A N/A N/A	No No No No	Byproduct of drinking water disinfection
THM (ppb) [total trihalomethanes] (Individual Sites)	80	N/A	A= (locational average)	44.95	10 to 61 (range of individual sites)	N/A	No	Byproduct of drinking water disinfection.

EPA has not established drinking water standards for unregulated contaminants. There are no MCL's and therefore no violations if found.

Secondary contaminants do not have a direct impact on the health of consumers and are not required in the Consumer Confidence Report. They are being included to provide additional information about the quality of the water.

Sodium	optimum level =20 mg/L	4	4 to 4	Mar-14
---------------	------------------------	---	--------	--------

One or more of the water systems we purchase water from violated one or more drinking water standards over the past year. Even though these were not emergencies, as our customers, you have a right to know what happened and what we did to correct the situation. The Russell Springs Water Dept. received a violation for failure to report the minimum daily chlorine residual samples throughout the distribution system in February 2014. The City of Jamestown Water Dept. received a violation for failure to collect and report the minimum daily chlorine residual samples throughout the distribution system on September 29 and 30, 2014. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During these times, they did not complete all reporting for daily chlorine residual and therefore cannot be sure of the quality of drinking water during that time. They have taken additional steps in the reporting process to ensure that this oversight will not happen in the future.